




# Certificate

Akku, 17.07.2008,15:53:09



Name: Entladekurve einer defekten Batterie  
Place of measurement:  
Instruments:: FOREX12V/420A  
Date:: 17.07.2008



## Measurement parameters

## Comment, other

1 Discharge 300 second 004,2 Ah

Batterie: 12V/24Ah

Sampling interval 5 second  
Discharge voltage: 10,80 V  
Discharge current: 50,0 A  
Cell number 6  
Measuremet No. 4  
- - -  
Voltage correction: 1  
Voltage offset: 0  
Current correction: 1  
Current offset: 0